



2820 S. English Station Road - Louisville, KY 40299

Test Report For Envitec Corporation

Test No.: 19-035-1

Date: 4/11/2019

Section 1

Summary

The Representative sample(s) have been tested, investigated, and found to comply with the requirements of

Standards:

Electrostatic Air Cleaners, UL 867, Section 40, Fifth Edition, August, 2011 Revision: September 16, 2016.

The Equipment identified in this report has been found to meet the criteria for emittance of ozone exceeding a concentration of 0.050 ppm where the average of any five consecutive one minute average measurements is less than 0.050 ppm. Blue Heaven Technologies has concluded that in both tests that the unit did not exceed the limit of 0.050 ppm.

This report completes our evaluation covered by Blue Heaven Technologies test number 19-035-1 which has been authorized by Blue Heaven Technologies P.O. . If there are any questions regarding the results contained in this report, or any of the other services offered by blue heaven technologies, please do not hesitate to contact the above signed.



2820 S. English Station Road - Louisville, KY 40299

Test #: 19-035-1

Date: 4/11/2019

Test Report For Envitec Corporation

Section 3

Unit Under Test Information

Model Information			
Manufacturer:	GPS by Nu-Calgon	Pre-Filter:	N/A
Model Number:	Iwave-R 4900-20	HEPA Filter:	N/A
Production/Prototype:	N/A	ESP Filter:	N/A
Fan Speeds:	N/A	Carbon Filter:	N/A
O3/ Voltage settings:	N/A	UV Light:	N/A
O3 Monitor:	N/A	Ionizer:	Yes
Model Notes:	Unit has no fan		

RUN-IN TEST			
FIRST SAMPLE			
Run-in Start:	3/26/2019	Run-in End:	3/27/2019
Run-in Temperature	73.4 F ±4 F	Tracking Number:	N/A
Serial Number:	4900-20		
Samples Notes:	Sample did not exceed 0.05 PPM		
SECOND SAMPLE			
Run-in Start:	3/28/2019 0:00	Run-in End:	3/29/2019 0:00
Run-in Temperature:	74.8 F ±4 F	Tracking Number	NA
Serial Number:	4900-20		
Samples Notes:	Sample did not exceed 0.05 PPM		